

Table 3M-8. Monthly Capacity, Energy Production, and Capacity Factor of Combined Aqueduct Generating Facilities, 1986-1990

	Jan.	Feb.	March	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Annual
<hr/>													
Capacity (MW)													
1986	196.0	196.0	196.0	196.0	196.0	196.0	196.0	196.0	196.0	196.0	196.0	196.0	196.0
1987-1990	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0
Energy (GWh)													
1986	89.1	78.7	109.4	129.9	111.8	86.7	94.0	108.8	132.7	110.2	98.6	98.6	1,248.5
1987	77.5	94.6	81.6	69.5	65.5	111.0	133.7	140.5	91.9	46.3	45.5	72.2	1,029.8
1988	73.7	77.2	95.3	71.9	63.4	74.0	97.7	112.5	41.6	33.1	49.2	71.8	861.4
1989	98.6	63.5	59.4	39.2	49.9	62.4	115.9	83.6	64.2	25.7	23.6	31.2	717.2
1990	34.2	25.5	27.2	31.4	33.2	30.4	28.8	23.4	12.3	20.9	13.1	12.5	292.9
Capacity Factor (%)													
1986	61.1	59.8	75.0	92.0	76.7	61.4	64.5	74.6	94.0	75.6	69.9	67.6	72.7
1987	52.1	70.4	54.8	48.3	44.0	77.1	89.9	94.4	63.8	31.1	31.6	48.5	58.8
1988	49.5	57.4	64.0	49.9	42.6	51.4	65.7	75.6	28.9	22.2	34.2	48.3	49.2
1989	66.3	47.2	39.9	27.2	33.5	43.3	77.9	56.2	44.6	17.3	16.4	21.0	40.9
1990	23.0	19.0	18.3	21.8	22.3	21.1	19.4	15.7	8.5	14.0	9.1	8.4	16.7

Sources: Singley and Neudeck pers. comms.
