

Table 3M-9. Annual Capacity, Energy Production, and Capacity Factor of Los Angeles Aqueduct Generating Facilities, by Subsystem, 1986-1990

| | Owens River Gorge Subsystem | Owens Valley Subsystem | Aqueduct Subsystem |
|---------------------|-----------------------------|------------------------|--------------------|
| Capacity (MW) | 110.0 | 9.0 | 81.0 ^a |
| Energy (GWh) | | | |
| 1986 | 542.0 | 91.7 | 614.8 |
| 1987 | 409.1 | 59.6 | 561.1 |
| 1988 | 322.1 | 48.9 | 490.4 |
| 1989 | 288.4 | 46.6 | 382.2 |
| 1990 | 121.5 | 26.8 | 144.6 |
| Capacity factor (%) | | | |
| 1986 | 56.2 | 116.3 | 91.1 |
| 1987 | 42.5 | 75.6 | 79.6 |
| 1988 | 33.4 | 62.0 | 69.1 |
| 1989 | 29.9 | 59.1 | 53.9 |
| 1990 | 12.6 | 34.0 | 20.4 |

^a In 1986, capacity was 77.0 MW.

Source: Singley and Neudeck pers. comms.